



March 1, 2022

ADDENDUM NO. 3

TO

CITY OF BEAUMONT, TEXAS
COLLIER'S FERRY PUMP STATION
BID No. WU0222-14

THIS ADDENDUM IS ISSUED FOR THE PURPOSE OF AMENDING THE CONTRACT DOCUMENTS FOR THE COLLIER'S FERRY PUMP STATION FOR THE CITY OF BEAUMONT, TEXAS:

The following additions, deletions, modifications, or clarifications shall be made to the appropriate sections of the plans and specifications and shall become part of the Contract Documents.

All bidders are herewith notified of the following additions, deletions, changes, or clarifications to the original Specifications, Contract Documents, and Contract Drawings.

When submitting the bid, bidders MUST acknowledge receipt of this Addendum No. 3 on the appropriate page within the bid specifications.

CLARIFICATIONS

1. Provided as an attachment is the Qualifications Statement in WORD format to allow for the required information to be submitted by bidders. This WORD file supersedes the PDF file previously uploaded on the City of Beaumont's website.
2. As attached on the following pages.

END OF ADDENDUM NO. 3

A handwritten signature in blue ink that reads "Amalia Villarreal".

Amalia Villarreal, P.E.
City Engineer

CITY UTILITIES

T 409.866.0026

F 409.861.4836



1350 Langham Road | Beaumont, TX 77707

beaumonttexas.gov

00 91 03 ADDENDUM NUMBER 3

Owner: City of Beaumont

Project: Collier's Ferry Pump Station

Project No.: BMT20326 (City Bid No. WU0222-14)

Addendum No. 3

Addendum Date: 3/01/2022

The following additions, deletions, modifications, or clarifications shall be made to the appropriate portions of the Contract Documents. Offerors must acknowledge receipt of this Addendum in the space provided on the Bid Form.

Approved by:	<u>Freese and Nichols</u>
Name:	<u>Somnath Chilukuri</u>
Date:	<u>3/01/2022</u>



FREESE AND NICHOLS, INC.
TEXAS REGISTERED
ENGINEERING FIRM
F-2144

Addendum Items:

*Article 3 – Revision to Specifications
Section 00 01 10 Table of Contents*

Article 5 – CivCast Questions

Qualification statement in word format

ARTICLE 1 – ADDENDUM

- 1.01 Amend the Contract Documents
 - A. Make the additions, modifications, or deletions to the Contract Documents described in this Addendum.
- 1.02 Acknowledge Addenda
 - A. Acknowledge receipt of this Addendum in the Bid Form submitted for this Project. Failure to acknowledge receipt of this addendum in the Bid Form may render the Bid as non-responsive and serve as the basis for rejecting the Bid.
- 1.03 Qualification statement in word format will be uploaded to CIVCAST as part of this addendum.
- 1.04 Addendum #2, Article 5, Paragraph 5.01: Delete the letters “February xx” and add the following: “February 24”.

ARTICLE 2 – BID REQUIREMENTS [NOT USED]

ARTICLE 3 – SPECIFICATIONS

- 3.01 00 01 10 Table of Contents
 - A. Add the following lines in Division 00:
 - 1. “00 91 03 Addendum Number 3”

ARTICLE 4 – DRAWINGS [NOT USED]

ARTICLE 5 – CIVCAST QUESTIONS

- 5.01 Questions and responses provided through CIVCAST through March 1, 2022 at 12pm are as follows:
 - 31. Sect #26 24 13 - 600V Switchboards: Part 2.01/R makes reference to a GRAPHIC USER INTERFACE TOUCH SCREEN. Does this apply to this project? If so, what is the intent of this requirement. Would appear this would apply for transfer scheme, that doesn't apply to this board. Please clarify.

Response - The switchboard GUI Touch Screen does not need to be provided as part of this contract.
 - 33. When should we expect to see the addendum with the sign in sheets from the Pre-bid meeting? It was previously stated that this would be provided in addendum #1, however, there has already been an addendum #1 issued.

Response – Sign in sheet will be posted with Addendum # 2 tomorrow.
 - 35. Can you make the qualification statement available in word format? This will be easier to fill in, as pages need to be added for Tables 2 and 7. Thank you.

Response – Qualification Statement in word format will be uploaded as part of Addendum #3.

36. Can the native file for the bid form be uploaded? The cells are too small to write in with the current version.

Response – Qualification Statement in word format will be uploaded as part of Addendum #3.

The remaining unanswered questions will be addressed in Addendum No. 4.

END OF ADDENDUM NO. 3

“Endress Hauser,”

3.09 44 42 56.04 Submersible Pumps

A. Paragraph 1.02.A

1. Add the following to Paragraph 1.02.A:

“3. ABS Sulzer”

ARTICLE 4 – DRAWINGS [NOT USED]

ARTICLE 5 – CIVCAST QUESTIONS

- 5.01 Questions and responses provided through CIVCAST through February 24, 2022 at 12pm are as follows:

2. Seeking approval of Val-Matic Butterfly Valve as named manufacturer in specification 40 05 64.

Response – Val-Matic will be added as an acceptable butterfly valve manufacturer in Specification Section 40 05 64 Paragraph 1.02.A.

3. ABB/GE is kindly requesting to be included as an acceptable manufacturer to supply Variable Frequency Drives (26 29 23.11).

Response - No changes are being made to the list of approved manufacturers for the electrical equipment.

4. ABB/GE is kindly requesting to be included as an acceptable manufacturer to supply 600V Switchboards (26 24 13).

Response - No changes are being made to the list of approved manufacturers for the electrical equipment.

5. Request approval of Waterman as an approved manufacturer of Fabricated Slide Gates per Section 40 05 50 1.02

Response – We will include Waterman as an acceptable manufacturer upon confirmation that they meet the project specifications.

6. Section: 40 05 61 Gate Valves: With 0-48” stocked in Utah with no long lead times – Can Av-Tek Water Valves knife gate valve be listed as an acceptable manufacturer?

Response – We will include Av-Tek as an acceptable manufacturer.

7. Section: 40 05 64 Butterfly Valves: With 0-48” stocked in Utah with no long lead times – Can Av-Tek Water Valves Dex Double Eccentric no leak guarantee for 3 years valves be listed as an acceptable manufacturer? Technical Info:

<http://www.avtekvalves.com/products/double-eccentric-butterfly-valve>

Response – We will include Av-Tek as an acceptable manufacturer if they meet the project specification. Please review project specification and confirm that Av-Tek meets the specification.

8. Section: 40 05 78 Air Release & Air & Vacuum Valves: - Can Av-Tek Water Valves Triple Function Air Release & Wastewater Combination Air Valve Mod. SCF 2 valves be listed as an acceptable manufacturer?